

Spill Summary Report for NRC Report #981160

Report Date: 9/14/2022

Report Time: 4:03 PM EDT

Region II Hotline Log Entry Information

Data ID: 1002976

Date Of Report: 6/29/2011

NRC #: 981160

State #: NYCDEP 185267672

ERNS #:

Material Type: Oil

Receiver: Haas

Material / Amount:

OIL, MISC: TRANSFORMER (300 GALLON(S)); POLYCHLORINATED BIPHENYLS (0 UNKNOWN AMOUNT);

Location:

Street:

City:

County: BRONX

State: NY

Latitude:

Longitude:

Source of Pollution:

CON EDISON

Water Body:

SEWER

State Or EPA Responded:

see action report, NYCDEP has been alerted to the incident

Initial EPA Action:

no response necessary

Status:

2 - Closed

URL:

Associated Action Reports

DataID: 0411429

Date: 6/29/2011	Time: 10:58	
Duty Officer/Responder Name: Haas	NRC Report #: 981160	Hotline Log DataID: 1002976
Action Information		
Description: Called RP (Con-Ed) it is still unknown if the oil contained PCBs. The exact address of the vault is east 156th Street at Park Ave. in the Bronx. The release was not entirely contained as some entered the combined sewer system and is headed for the local wastewater treatment plant. Con Ed will clean out the remainder of the vault, drain and remove the transformer.		
Follup-Up:		
Person Contacted		
Name: Organization: Con-Ed ERT Phone #: 212-580-6763		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 981160

INCIDENT DESCRIPTION

*Report taken by: CIV NICHOLAUS THREATT at 10:15 on 29-JUN-11

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE

Affected Area: SEWER

The incident occurred on 29-JUN-11 at 09:45 local time.

Affected Medium: WATER SEWER

REPORTING PARTY

Name: THOMAS ENRIGHT

Organization: CON EDISON

Address: 128 WEST END AVE.

NEW YORK, NY 10003

CON EDISON called for the responsible party.

PRIMARY Phone: (212)5806763

INCIDENT LOCATION

County: BRONX

State: NY

VAULT 612

RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER

Also Known As:

Qty Released: 300 GALLON(S)

Qty in Water: 0 UNKNOWN AMOUNT

CHRIS Code: PCB Official Material Name: POLYCHLORINATED BIPHENYLS

Also Known As:

Qty Released: 0 UNKNOWN AMOUNT

Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER IS REPORTING A DISCHARGE OF TRANSFORMER OIL FROM AN UNDERGROUND TRANSFORMER
DERIVED FROM A VAULT DUE TO AN EQUIPMENT FAILURE. CALLER DOES NOT KNOW IF THE
TRANSFORMER CONTAINS PCB AT THIS TIME.

SENSITIVE INFORMATION

INCIDENT DETAILS

Package: NO
Building ID:
Type of Fixed Object: TRANSFORMER
Power Generating Facility: NO
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

---WATER INFORMATION---

Body of Water: SEWER
Tributary of: UNKNOWN
Nearest River Mile Marker:
Water Supply Contaminated: YES

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: THOMAS ENRIGHT
Organization: CON EDISON
Address: 128 WEST END AVE.
NEW YORK, NY 10003
PRIMARY Phone: (212)5806763
Type of Organization: PUBLIC UTILITY

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:
Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air: N			
Road: N			Major Art _N
Waterway: N			
Track: N			

Passengers Transferred: NO
Environmental Impact: UNKNOWN
Media Interest: NONE Community Impact due to Material:

REMEDIAL ACTIONS

CALLER IS MAKING NOTIFICATIONS.
Release Secured: UNKNOWN
Release Rate:
Estimated Release Duration:

WEATHER

Weather: CLEAR, 73°F

ADDITIONAL AGENCIES NOTIFIED

Federal: NONE
State/Local: NONE
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

ATLANTIC STRIKE TEAM (MAIN OFFICE)
29-JUN-11 10:19 (609)7240008
DHS NOC (NOC)
29-JUN-11 10:19 (202)2828114
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)
29-JUN-11 10:19 (202)3661863
U.S. EPA II (MAIN OFFICE)
(732)3214370

FEDERAL EMERGENCY MANAGEMENT AGENCY (MAIN OFFICE)
29-JUN-11 10:19 (800)6347084
INFO ANALYSIS & INFRA PROTECTION (MAIN OFFICE)
29-JUN-11 10:19
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)
29-JUN-11 10:19 (202)2829201
NATIONAL INFRASTRUCTURE COORD CTR (INFRASTRUCTURE PROTECTION)
29-JUN-11 10:19 (202)2829201
NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)
29-JUN-11 10:19 (609)9636817
NJ STATE POLICE (MARINE SERVICES BUREAU)
29-JUN-11 10:19 (609)9636900
NOAA RPTS FOR NY (MAIN OFFICE)
29-JUN-11 10:19 (206)5264911
BUREAU TOXIC SUBSTANCE R. WILBURN (MAIN OFFICE)
29-JUN-11 10:19 (518)4027810
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)
29-JUN-11 10:19 (518)4577362
HOMELAND SEC COORDINATION CENTER (MAIN OFFICE)
29-JUN-11 10:19 (202)2828300
SECTOR NEW YORK (COMMAND CENTER)
(718)3544353
NJ DEP POC: DUTY OFFICER (MAIN OFFICE)
29-JUN-11 10:19 (609)5844551
USCG DISTRICT 1 (COMMAND CENTER)
29-JUN-11 10:19 (617)2238555

ADDITIONAL INFORMATION

CALLER WILL NOTIFY STATE AND LOCAL AGENCIES.

*** END INCIDENT REPORT # 981160 ***

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>